SUMMARY

Applicant: Stimson Land L.T.D.

Facility Name

and Address: Northstar Winery

1736 J.B. George Road Walla Walla, WA 99362

Type of

<u>Treatment</u>: Membrane Lined, non-overflow lagoon

<u>Design Flow:</u> 2325 maximum daily flow, 418,000 gallons per year

POTW

<u>Location</u>: 1736 J.B. George Road

Walla Walla, WA 99362

NW¹/₄, SW¹/₄, Sec⁷, T.6 N., R.36 E.W.M.

Latitude: 46° 35' 00"N

Longitude: 118° 22' 30"W

TABLE OF CONTENTS

INTRODUCTION	1
BACKGROUND INFORMATION	3
DESCRIPTION OF THE COLLECTION AND TREATMENT SYSTEM	
History	
Collection System Status	
Treatment Processes	
Residual Solids	
GROUND WATER	
PERMIT STATUS	
WASTEWATER CHARACTERIZATION	
SEPA COMPLIANCE	
PROPOSED PERMIT LIMITATIONS	4
TECHNOLOGY-BASED EFFLUENT LIMITATIONS	5
MONITORING REQUIREMENTS	5
INFLUENT AND EFFLUENT MONITORING	5
OTHER PERMIT CONDITIONS	5
REPORTING AND RECORDKEEPING	
FACILITY LOADING	
OPERATIONS AND MAINTENANCE	
RESIDUAL SOLIDS HANDLING	
PRETREATMENT	
GENERAL CONDITIONS	6
RECOMMENDATION FOR PERMIT ISSUANCE	7
REFERENCES FOR TEXT AND APPENDICES	7
APPENDICES	8
APPENDIX APUBLIC INVOLVEMENT INFORMATION	
APPENDIX BGLOSSARY	9
APPENDIX C—SITE MAP	
APPENDIX DRESPONSE TO COMMENTS	13

INTRODUCTION

This fact sheet is a companion document to the draft State Waste Discharge Permit No. **ST-8083**The Department of Ecology (the Department) is proposing to issue this permit, which will allow discharge of wastewater to waters of the State of Washington. This fact sheet explains the nature of the proposed discharge, the Department's decisions on limiting the pollutants in the wastewater, and the regulatory and technical bases for those decisions.

Washington State law (RCW 90.48.080 and 90.48.162) requires that a permit be issued before discharge of wastewater to waters of the state is allowed. Regulations adopted by the State include procedures for issuing permits (Chapter 173-216 WAC), technical criteria for discharges from municipal wastewater treatment facilities (Chapter 173-221 WAC) and water quality criteria for ground waters (Chapter 173-200 WAC). They also establish the basis for effluent limitations and other requirements which are to be included in the permit.

This fact sheet and draft permit are available for review by interested persons as described in Appendix A--Public Involvement Information.

The fact sheet and draft permit have been reviewed by the Permittee. Errors and omissions identified in these reviews have been corrected before going to public notice. After the public comment period has closed, the Department will summarize the substantive comments and the response to each comment. The summary and response to comments will become part of the file on the permit and parties submitting comments will receive a copy of the Department's response. The fact sheet will not be revised. Changes to the permit will be addressed in Appendix D-Response to Comments

GENERAL INFORMATION			
Applicant	Stimson Lane L.T.D.		
Facility Name and Address	Northstar Winery; 1736 J. B. George Road; Walla Walla, WA 99362		
Type of Treatment System:	Membrane-lined, non-overflow lagoon		
Discharge Location	Latitude: 46° 35' 00" N Longitude: 118° 22' 30	"W.	
Legal Description of Application Area	NW ¹ / ₄ , SW ¹ / ₄ , Sec7, T.6 N., R.36 E.W.M. Latitude: 46° 35' 00" N. Longitude: 118° 22' 30"W.		
Contact at Facility	Name: Rob McKinney Telephone #: (509) 875-2001		
Responsible Official	Name: Glenn C. Coogan Title: Vice President, Washington Operations Address: P.O. Box 1976; Woodinville, WA 98072 Telephone #: (425) 488-1133		

GENERAL INFORMATION	
	FAX #: (425) 415-3657

BACKGROUND INFORMATION

DESCRIPTION OF THE COLLECTION AND TREATMENT SYSTEM

HISTORY

Northstar Winery is a wholly owned subsidiary of Stimson-Lane Vineyards & Estates, which is itself a subsidiary of the UST, Inc., formerly the U.S. Tobacco Company. Stimson-Lane Vineyards & Estates includes Chateau Ste. Michelle, Columbia Crest Cellar, Coventry Vale, and Paul Thomas in its stable. The new \$3M Northstar Winery facility in Walla Walla, was dedicated on September 20, 2002.

Northstar Winery expects to produces about 5000 cases of ultra premium red wines. At the end of a five year period, ending in 2006, Northstar expects to produce 20,000 cases or 47,500 gallons of finished wine.

An estimation of the proportions that are assigned to each waste stream at harvest peak are as follows:

#1 Crush pad and press areas	55% of wastewater volume	1015 gallons per day
#2 Tank room	30% of wastewater volume	554 gallons per day
#3 Barrel room & barrel wash	10% of wastewater volume	185 gallons per day
#4 Bottling area	5% of wastewater volume	92 gallons per day

Wastewater flows are expected to be no greater than 2350 gallons/day maximum daily flow, at final design capacity of 20,000 cases of wine. At that flow, the total annual wastewater discharge is estimated at no more than 175,000 gallons/year. Sanitary wastewater is handled by an on-site septic tank and drainfield that is distinct from the process wastewater system.

COLLECTION SYSTEM STATUS

The process wastewater is collected from the processing building and gravity flows to a 2500 gallon septic tank, which also serves as the pump station for discharge to the membrane lined evaporation lagoon.

TREATMENT PROCESSES

The evaporation lagoon is 80 feet square with a maximum operating depth of 6.5 feet. The lagoon is aerated and is lined with a 30 mil impermeable membrane liner.

- RESIDUAL SOLIDS

The treatment facilities remove solids during the treatment of the wastewater in the lift station and perhaps some sludge in the aerated lagoon. The bulk of the solids generated in the processing of the wine will be removed prior to discharge to the industrial wastewater system.

Organic solids removed from the processing of wine will be land applied, using standard winery practices.

GROUND WATER

It is estimated that the groundwater is 32 feet below the finished floor of the basement level. Beyond the groundwater level of 803.5, the statement is made that there was no appreciable evidence of mottling above the measured groundwater table. This was assumed to indicate that either the groundwater is at a seasonal high or it is stable. The bottom elevation of the lined lagoon is about elevation 850 or about 46.5 feet above the groundwater. In any event, at this time, wastewater is stored in the lined pond and not discharged to the environment.

PERMIT STATUS

This is a new facility. An application for a permit was submitted to the Department on December 14, 2001 and accepted by the Department in 2002.

WASTEWATER CHARACTERIZATION

The concentration of pollutants in the discharge was estimated in the application and the engineering, based on literature sources and from the St. Michelle winery in Grandview, WA. The proposed wastewater discharge into the lined storage pond is estimated for the following parameters:

Table 1: Wastewater Characterization

<u>Parameter</u>	Concentration
BOD	5000 mg/l
TSS	2,000 mg/l
Total Nitrogen	250 mg/l

SEPA COMPLIANCE

SEPA for the Northstar Winery construction was completed in 2001.

PROPOSED PERMIT LIMITATIONS

State regulations require that limitations set forth in a waste discharge permit must be either technology- or water quality-based. Wastewater must be treated using all known, available, and reasonable treatment (AKART) and not pollute the waters of the State. The minimum requirements to demonstrate compliance with the AKART standard are derived from the *Water Reclamation and Reuse Standards*, the *Design Criteria for Municipal Wastewater Land Treatment*, and Chapter 173-221 WAC. It was determined that retention in a lined pond of the wastewater liquids is AKART for this type of facility.

The more stringent of the water quality-based or technology-based limits are applied to each of the parameters of concern. Each of these types of limits is described in more detail below.

TECHNOLOGY-BASED EFFLUENT LIMITATIONS

All waste discharge permits issued by the Department must specify conditions requiring available and reasonable methods of prevention, control, and treatment of discharges to waters of the state (WAC 173-216-110).

MONITORING REQUIREMENTS

Monitoring, recording, and reporting are specified to verify that the treatment process is functioning correctly, that ground water criteria are not violated, and that effluent limitations are being achieved (WAC 173-216-110).

INFLUENT AND EFFLUENT MONITORING

The monitoring and testing schedule is detailed in the proposed permit under Condition S2. Specified monitoring frequencies take into account the quantity and variability of the discharge, the treatment method, past compliance, significance of pollutants, and cost of monitoring.

OTHER PERMIT CONDITIONS

REPORTING AND RECORDKEEPING

The conditions of S3. are based on the authority to specify any appropriate reporting and recordkeeping requirements to prevent and control waste discharges (WAC 173-216-110).

FACILITY LOADING

The design criteria for this treatment facility are taken from 2000 engineering analysis prepared by SCM Consultants, Inc. and are as follows:

Monthly average wet weather flow:	1550 gpd
Maximum daily discharge flow:	2325 gpd
BOD influent loading:	5000 mg/l
TSS influent loading:	2000 mg/l
Total nitrogen influent loading:	250 mg/l

The permit requires the Permittee to maintain adequate capacity to treat the flows and waste loading to the treatment plant (WAC 173-216-110[4]). The Permittee is required to submit an engineering report when the plant reaches 85% of its flow or loading capacity. For significant new discharges, the permit requires a new application and an engineering report (WAC 173-216-110[5]). The permit requires the Permittee to submit annual reports comparing the actual flow and waste loadings to the design criteria for the plant.

OPERATIONS AND MAINTENANCE

The proposed permit contains condition S.5. as authorized under RCW 90.48.110, WAC 173-220-150, Chapter 173-230 WAC, and WAC 173-240-080. It is included to ensure proper operation and regular maintenance of equipment, and to ensure that adequate safeguards are taken so that constructed facilities are used to their optimum potential in terms of pollutant capture and treatment.

RESIDUAL SOLIDS HANDLING

To prevent water pollution the Permittee is required in permit condition S6. to store and handle all residual solids (grit, screenings, scum, sludge, and other solid waste) in accordance with the requirements of RCW 90.48.080 and State Water Quality Standards.

The final use and disposal of sewage sludge from this facility is regulated by U.S. EPA under 40 CFR 503 and by Ecology under Chapter 70.95J RCW and Chapter 173-208 WAC. The disposal of other solid waste is under the jurisdiction of the local health district.

Requirements for monitoring sewage sludge and recordkeeping are included in this permit. This information will by used by Ecology to develop or update local limits and is also required under 40 CFR 503.

PRETREATMENT

WAC 173-216-110 requires that the list of prohibitions in WAC 173-216-060 be included in the permit.

Federal pretreatment requirements in 40 CFR 403 and Sections 307(b) and 308 of the Clean Water Act apply to this facility. Therefore notification to the Department is required when pretreatment prohibitions are violated and when new sources of commercial or industrial wastewater discharge are added to its system.

GENERAL CONDITIONS

General Conditions are based directly on state laws and regulations and have been standardized for all industrial waste discharge to ground water permits issued by the Department.

Condition G1 requires responsible officials or their designated representatives to sign submittals to the Department. Condition G2 requires the Permittee to allow the Department to access the treatment system, production facility, and records related to the permit. Condition G3 specifies conditions for modifying, suspending or terminating the permit. Condition G4 requires the Permittee to apply to the Department prior to increasing or varying the discharge from the levels stated in the permit application. Condition G5 requires the Permittee to submit written notice of significant increases in the amount or nature of discharges (typically new industrial discharges) into the sewer system tributary to the permitted facility. Condition G6 requires the Permittee to construct, modify, and operate the permitted facility in accordance with approved engineering documents. Condition G7 prohibits the Permittee from using the permit as a basis for violating any laws, statutes or regulations. Condition G8 requires application for permit renewal 60 days

prior to the expiration of the permit. Condition G9 requires the payment of permit fees. Condition G10 describes the penalties for violating permit conditions.

RECOMMENDATION FOR PERMIT ISSUANCE

This proposed permit meets all statutory requirements for authorizing a wastewater discharge, including those limitations and conditions believed necessary to control toxics, and to protect human health and the beneficial uses of waters of the State of Washington. The Department proposes that the permit be issued for five years.

REFERENCES FOR TEXT AND APPENDICES

Washington State Department of Ecology, 1993. <u>Guidelines for Preparation of Engineering</u> <u>Reports for Industrial Wastewater Land Application Systems</u>, Ecology Publication # 93-36. 20 pp.

Washington State Department of Ecology and Department of Health, 1997. <u>Water Reclamation and Reuse Standards</u>, Ecology Publication # 97-23. 73 pp.

Washington State Department of Ecology.

Laws and Regulations(http://www.ecy.wa.gov/laws-rules/index.html)

Permit and Wastewater Related Information (http://www.ecy.wa.gov/programs/wq/wastewater/index.html)

Washington State Department of Ecology, 1996. <u>Implementation Guidance for the Ground Water Quality Standards</u>, Ecology Publication # 96-02.

Washington State University, November, 1981. <u>Laboratory Procedures - Soil Testing</u> Laboratory. 38 pp.

APPENDICES

APPENDIX A--PUBLIC INVOLVEMENT INFORMATION

The Department has tentatively determined to issue a permit to the applicant listed on page one of this fact sheet. The permit contains conditions and effluent limitations which are described in the rest of this fact sheet.

Public notice of application was published on January 26 and February 2, 2004 in the Walla Walla Union Bulletin to inform the public that an application had been submitted and to invite comment on the reissuance of this permit.

The Department will publish a Public Notice of Draft (PNOD) on February 12, 2004 in the Walla Walla Union Bulletin to inform the public that a draft permit and fact sheet are available for review. Interested persons are invited to submit written comments regarding the draft permit. The draft permit, fact sheet, and related documents are available for inspection and copying between the hours of 8:00 a.m. and 5:00 p.m. weekdays, by appointment, at the regional office listed below. Written comments should be mailed to:

Water Quality Permit Coordinator Department of Ecology Eastern Regional Office 4601 North Monroe Street Spokane, Washington 99205-1295

Any interested party may comment on the draft permit or request a public hearing on this draft permit within the thirty (30) day comment period to the address above. The request for a hearing shall indicate the interest of the party and reasons why the hearing is warranted. The Department will hold a hearing if it determines there is a significant public interest in the draft permit (WAC 173-216-100). Public notice regarding any hearing will be circulated at least thirty (30) days in advance of the hearing. People expressing an interest in this permit will be mailed an individual notice of hearing.

Comments should reference specific text followed by proposed modification or concern when possible. Comments may address technical issues, accuracy and completeness of information, the scope of the facility's proposed coverage, adequacy of environmental protection, permit conditions, or any other concern that would result from issuance of this permit.

The Department will consider all comments received within thirty (30) days from the date of public notice of draft indicated above, in formulating a final determination to issue, revise, or deny the permit. The Department's response to all significant comments is available upon request and will be mailed directly to people expressing an interest in this permit.

Further information may be obtained from the Department by telephone, (509) 329-3426, or by writing to the address listed above.

This permit was written by Andrew K.S.Tom.

APPENDIX B--GLOSSARY

Ammonia--Ammonia is produced by the breakdown of nitrogenous materials in wastewater. Ammonia is toxic to aquatic organisms, exerts an oxygen demand, and contributes to eutrophication. It also increases the amount of chlorine needed to disinfect wastewater.

Average Monthly Discharge Limitation--The average of the measured values obtained over a calendar month's time.

Best Management Practices (BMPs)--Schedules of activities, prohibitions of practices, maintenance procedures, and other physical, structural and/or managerial practices to prevent or reduce the pollution of waters of the State. BMPs include treatment systems, operating procedures, and practices to control: plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage. BMPs may be further categorized as operational, source control, erosion and sediment control, and treatment BMPs.

 BOD_5 --Determining the Biochemical Oxygen Demand of an effluent is an indirect way of measuring the quantity of organic material present in an effluent that is utilized by bacteria. The BOD_5 is used in modeling to measure the reduction of dissolved oxygen in a receiving water after effluent is discharged. Stress caused by reduced dissolved oxygen levels makes organisms less competitive and less able to sustain their species in the aquatic environment. Although BOD is not a specific compound, it is defined as a conventional pollutant under the federal Clean Water Act.

Chlorine--Chlorine is used to disinfect wastewaters of pathogens harmful to human health. It is also extremely toxic to aquatic life.

Compliance Inspection - Without Sampling--A site visit for the purpose of determining the compliance of a facility with the terms and conditions of its permit or with applicable statutes and regulations.

Compliance Inspection - With Sampling--A site visit to accomplish the purpose of a Compliance Inspection - Without Sampling and as a minimum, sampling and analysis for all parameters with limits in the permit to ascertain compliance with those limits; and, for municipal facilities, sampling of influent to ascertain compliance with the 85 percent removal requirement. Additional sampling may be conducted.

Composite Sample--A mixture of grab samples collected at the same sampling point at different times, formed either by continuous sampling or by mixing discrete samples. May be "time-composite" (collected at constant time intervals) or "flow-proportional" (collected either as a constant sample volume at time intervals proportional to stream flow, or collected by increasing the volume of each aliquot as the flow increased while maintaining a constant time interval between the aliquots.

Construction Activity--Clearing, grading, excavation and any other activity which disturbs the surface of the land. Such activities may include road building, construction of residential houses, office buildings, or industrial buildings, and demolition activity.

Continuous Monitoring –Uninterrupted, unless otherwise noted in the permit.

Engineering Report--A document, signed by a professional licensed engineer, which thoroughly examines the engineering and administrative aspects of a particular domestic or industrial wastewater facility. The report shall contain the appropriate information required in WAC 173-240-060 or 173-240-130.

Grab Sample--A single sample or measurement taken at a specific time or over as short period of time as is feasible.

Industrial Wastewater--Water or liquid-carried waste from industrial or commercial processes, as distinct from domestic wastewater. These wastes may result from any process or activity of industry, manufacture, trade or business, from the development of any natural resource, or from animal operations such as feed lots, poultry houses, or dairies. The term includes contaminated storm water and, also, leachate from solid waste facilities.

Maximum Daily Discharge Limitation--The highest allowable daily discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. The daily discharge is calculated as the average measurement of the pollutant over the day.

pH--The pH of a liquid measures its acidity or alkalinity. A pH of 7 is defined as neutral, and large variations above or below this value are considered harmful to most aquatic life.

Soil Scientist--An individual who is registered as a Certified or Registered Professional Soil Scientist or as a Certified Professional Soil Specialist by the American Registry of Certified Professionals in Agronomy, Crops, and Soils or by the National Society of Consulting Scientists or who has the credentials for membership. Minimum requirements for eligibility are: possession of a baccalaureate, masters, or doctorate degree from a U.S. or Canadian institution with a minimum of 30 semester hours or 45 quarter hours professional core courses in agronomy, crops or soils, and have 5,3,or 1 years, respectively, of professional experience working in the area of agronomy, crops, or soils.

State Waters--Lakes, rivers, ponds, streams, inland waters, underground waters, salt waters, and all other surface waters and watercourses within the jurisdiction of the state of Washington.

Stormwater--That portion of precipitation that does not naturally percolate into the ground or evaporate, but flows via overland flow, interflow, pipes, and other features of a storm water drainage system into a defined surface water body, or a constructed infiltration facility.

Technology-based Effluent Limit--A permit limit that is based on the ability of a treatment method to reduce the pollutant.

Total Coliform Bacteria--A microbiological test which detects and enumerates the total coliform group of bacteria in water samples.

Total Dissolved Solids--That portion of total solids in water or wastewater that passes through a specific filter.

Total Suspended Solids (TSS)--Total suspended solids is the particulate material in an effluent. Large quantities of TSS discharged to a receiving water may result in solids accumulation. Apart from any toxic effects attributable to substances leached out by water, suspended solids may kill fish, shellfish, and other aquatic organisms by causing abrasive injuries and by clogging the gills and respiratory passages of various aquatic fauna. Indirectly, suspended solids can screen out light and can promote and maintain the development of noxious conditions through oxygen depletion.

Water Quality-based Effluent Limit--A limit on the concentration of an effluent parameter that is intended to prevent pollution of the receiving water.

APPENDIX C—SITE MAP

APPENDIX D--RESPONSE TO COMMENTS